

ARKANSAS STATE HIGHWAY
AND
TRANSPORTATION DEPARTMENT

Scott E. Bennett
Director
Telephone (501) 569-2000
Voice/TTY 711



P.O. Box 2261
Little Rock, Arkansas 72203-2261
Telefax (501) 569-2400
www.arkansashighways.com

April 23, 2013

Mr. Robert Antoinette
Staff Engineer
Powers Fasteners Inc.
2 Powers Lane
Brewster, New York 10509

Ref: Pure110+

Dear Mr. Antoinette:

The request for acceptance of the referenced product on Qualified Products List (QPL) 507.03, Resin Anchoring Systems (for Installation of Dowel Bars & Tie Bars in Concrete Pavement and Extending Reinforced Concrete Box Culverts), has been reviewed. Pure110+ complies with the requirements in the QPL and the properties of ASTM C 881 / AASHTO M 235 Type IV, Grade 3, Class B and C.

A Certification Agreement with each manufacturer (or marketer for privately labeled products) must be in effect before a product can be placed on the QPL. Please review the enclosed agreement. If you agree to furnish material according to the terms stated, fill out the agreement appropriately and sign and return the original. It is important that the indicated QPL listing match with the labeling on the product container, and any certifications or documentation that would be supplied with the product. Upon receipt of the signed copy of the certification agreement, Pure110+ will be included as indicated. Initial approval of a product and its inclusion in a QPL is an acceptance of a particular product formulation or composition. Any change in that formulation or composition requires a new approval of the material.

If you have any questions, please contact the Materials Division at the above postal address, or phone (501) 569-2185, fax (501) 569-2368.

Sincerely,


Michael C. Benson
Materials Engineer

MCB:DWR
enclosure