



INDIANA DEPARTMENT OF TRANSPORTATION

Division of Materials and Tests
120 South Shortridge Road
Indianapolis, IN 46219

PHONE: (855) 463-6848
FAX: (317) 356-9351

Eric Holcomb, Governor
Michael Smith, Commissioner

June 29, 2023

DeWALT
701 East Joppa Road
Towson, MD 21286

Attention: Bob Antoinette, P.E.
Sr. Project Engineer

Subject: Pure220+ as Epoxy Adhesive Anchoring System

Dear Mr. Antoinette,

Your submittal for DeWalt Pure220+ for INDOT approval was reviewed and found to be in accordance with 901.05 of the INDOT Standard Specifications. The sample of DeWalt Pure220+ was successfully tested in accordance with INDOT ITM 807. The System withstood applied tensile load at 7,200 lbs/min until the load reached 36,000 lbs, the yield of a #7 bar required for INDOT approval; therefore, the product was added to INDOT qualified products list for Chemical Anchor Systems.

Installation of a chemical anchor systems on an INDOT contract shall be in accordance with the instructions provided by the manufacturer and subject to restrictions described in QPL. Maintaining approval of Pure220+ shall be in accordance with Section 11.2 of ITM 806.

If you have any questions, please contact Irina Goloschokin at 317-522-9676.

Respectfully,

Michael W. Nelson

Michael W. Nelson, PE
Concrete Materials Engineer

MWN/IBG/ig
c: I. Goloschokin – file

ITM 807-20 https://www.in.gov/indot/doing-business-with-indot/files/807_testing.pdf